

### **327 IAC 8-13-13 Reporting requirements**

**Authority:**

**Affected:**

**Sec. 13. All suppliers of water for community water systems shall submit a Monthly Report of Operation (MRO) on forms prescribed by the commissioner. Computer generated forms are acceptable if, at a minimum, all the required data are submitted on the form, and the form must be submitted and received for approval by the commissioner prior to use. Reports shall include the following data if applicable:**

- (1) Daily quantities of water pumped.**
- (2) Daily quantities of chemicals added to the water.**
- (3) Daily operation of treatment processes, including backwashing of filters by time and gallons of wash.**
- (4) Results of chemical, physical, or other tests performed for plant control.**
- (5) Calculated theoretical daily residuals and residual test results, both at the plant and out in the distribution system.**
- (6) Weekly groundwater depth measurements, both static and pumping measurements where applicable.**
- (7) Totals and averages of the above measurements where spaces are provided on the report form.**
- (8) Other data determined necessary by the commissioner.**

**All MRO's shall be submitted no later than ten (10) days after the end of each month. All MRO's shall be kept for a period of five (5) years.**